

# 2021 Consumer Confidence Report for Public Water System BASTROP COUNTY MUD 1

This is your water quality report for January 1 to December 31, 2021

For more information regarding this report contact:

BASTROP COUNTY MUD 1 provides ground water from the Carrizo - Wilcox aquifer located in Bastrop County.

Name: Bastrop County MUD #1

Phone: 512-402-1990

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (512) 402-1990.

## Definitions and Abbreviations

### Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

### Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

### Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

### Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

### Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

### Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

### Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

### Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

### Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

### MFL

million fibers per liter (a measure of asbestos)

### mrem:

millirems per year (a measure of radiation absorbed by the body)

### na:

not applicable.

### NTU

nephelometric turbidity units (a measure of turbidity)

### pCi/L

picocuries per liter (a measure of radioactivity)

## Definitions and Abbreviations

ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Information about Source Water

BASTROP COUNTY MUD 1 purchases water from AQUA WSC. AQUA WSC provides purchase ground water from the Carrizo - Wilcox aquifer located in Bastrop County.

TCEQ completed a Source Water Susceptibility for all drinking water systems that own their sources. This report describes the susceptibility and types of constituents that may come into contact with the drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system contact Bastrop County MUD #1 at 512-402-1990.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2020	1.3	1.3	0.2	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2020	0	15	2.7	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

## 2021 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
--------------------------	-----------------	------------------------	-----------------------------	------	-----	-------	-----------	--------------------------------

<b>Haloacetic Acids (HAA5)</b>	2021	5.6	5.6 - 5.6	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
<b>Total Trihalomethanes (TTHM)</b>	2021	25.6	25.6 - 25.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

<b>Inorganic Contaminants</b>	<b>Collection Date</b>	<b>Highest Level Detected</b>	<b>Range of Individual Samples</b>	<b>MCLG</b>	<b>MCL</b>	<b>Units</b>	<b>Violation</b>	<b>Likely Source of Contamination</b>
<b>Nitrate [measured as Nitrogen]</b>	2021	0.08	0.08 - 0.08	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

### Disinfectant Residual

From 2021 DLQOR's

<b>Disinfectant Residual</b>	<b>Year</b>	<b>Average Level</b>	<b>Range of Levels Detected</b>	<b>MRDL</b>	<b>MRDLG</b>	<b>Unit of Measure</b>	<b>Violation (Y/N)</b>	<b>Source in Drinking Water</b>
Chlorine	2021	1.54	1.34 - 2.0	4	4	ppm	N	Water additive used to control microbes.



# 2021 Provider Water Quality Test Results from AQUA WSC

## Aqua Water Supply Corporation 2021 Safe Drinking Water Sample Results

### Radiochemicals

Contaminate (Units)	MCL	MCLG	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2017	2017	2017	2017	2017	2017	2017	2021	2017	2020	2021	2021			
Gross Beta Particles (pCi/L)	50	0	<4.0	<4.0	<4.0	<4.0	5.0	<4.0	<4.0	<4.0	5.7	5.2	5.4	4.4	<4.0-5.7	5.7	Decay of natural and man-made deposits.
Radium 228 (pCi/L) 226/228	5	0	<1.0	<1.0	<1.0	1.15	<1.0	<1.0	<1.0	<1.0	<1.0	1.53	<1.0	<1.0	<1.0-1.53	1.53	Erosion of natural deposits.
Gross Alpha Excluding Radon/Uranium (pCi/L)	15	0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0			Erosion of natural deposits.
Gross Alpha Including Radon/Uranium (pCi/L)	15	0										<3.0					Erosion of natural deposits.
Uranium (ppb)	30	0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			Erosion of natural deposits.

### Inorganics (All Metals)

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2020	2020	2020	2020	2020	2019	2019	2021	2019	2020	2021	2021			
Total Hardness as CaCO <sub>3</sub> , by Cal. (mg/L.)			13.5	55.3	158	43.9	220	45.0	2.87	178	173	129	22.4	152			
Aluminum (mg/L.)			<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02			
Antimony (ppb)	6	6	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Arsenic (ppb)	10	0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium (ppm)	2	2	0.0656	0.0816	0.1450	0.128	0.119	0.0372	0.0124	0.1100	0.0361	0.142	0.0797	0.0798	0.0124-0.145	0.145	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Beryllium (ppb)	4	4	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80			Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries.
Cadmium (ppb)	5	5	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints.
Calcium (mg/L.)			3.43	12	48	11.3	72.6	11.8	1.15	55.1	47.2	38.3	6	35.1			
Chromium (ppb)	100	100	<10	<10	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0			Discharge from steel and pulp mills; Erosion of natural deposits.
Copper (mg/L.)			0.013	0.017	0.025	0.0202	0.0095	0.0103	0.0113	0.0026	0.0296	0.0078	<0.002	0.003			
Iron (mg/L.)			0.014	0.036	0.011	0.066	0.035	0.062	0.017	0.012	0.016	<0.01	0.014	<0.01			
Lead (mg/L.)			<0.001	<0.001	<0.001	<0.001	0.0024	<0.001	<0.001	<0.001	0.0014	<0.001	<0.001	<0.001			
Magnesium (mg/L.)			1.21	6.15	9.26	3.82	9.45	3.78	<1.00	9.72	13.3	8.07	1.8	15.7			
Manganese (mg/L.)			0.007	0.0169	0.0016	0.0201	0.0042	0.0148	0.0021	<0.001	0.0017	<0.001	0.0011	<0.001			
Mercury (ppb)	2	2	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40			Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland.
Nickel (mg/L.)			<0.001	<0.001	<0.001	<0.001	0.0015	<0.001	<0.001	0.001	0.0015	<0.001	0.0079	<0.001			
Potassium (mg/L.)			2.11	2.36	2.46	2.33	3.00	3.15	<1.00	2.58	4.4	3.18	5.73	3.51			
Selenium (ppb)	50	50	<3.0	5.2	5.5	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0-5.5	5.5	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Silver (mg/L.)			<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01			
Sodium (mg/L.)			172	256	77.7	73.6	27.4	119	102	54.6	61.2	68.1	15.6	113			
Thallium (ppb)	0.5	2	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40			Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories.
Zinc (mg/L.)			0.0052	<0.005	0.0121	0.0118	<0.005	0.0057	0.011	<0.005	0.0209	<0.005	0.0334	<0.005			
Non Regulated																	

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Inorganics (Single Mineral)**

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020			
Cyanide (ppb)	200	200	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	30	<10.0	<10.0	<10.0	<10.0	<10.0			Discharge from steel/metal factories; Discharge from plastic and fertilizer factories.



**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Inorganics (Minerals)**

Constituent	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2020	2020	2020	2020	2020	2020	2020	2021	2020	2020	2021	2021			
pH (S.U.)			8.5	7.4	7.7	7.6	7.4	7	7.8	8.1	7.7	7.7	8.5	8.4			
Diluted Conductance (µmho/cm)			765	1300	735	423	644	684	441	604	693	596	150	831			
Phenolphthalein Alkalinity as CaCO <sub>3</sub> (mg/L)			<2	<2	<2	<2	<2	<2	<2	<10	<2	<2	<10	<10			
Total Alkalinity as CaCO <sub>3</sub> (mg/L)			369	429	212	174	180	217	185	203	176	205	16	249			
Bicarbonate (mg/L)			450	523	259	212	220	265	226	248	215	250	20	300			
Carbonate (mg/L)			<2	<2	<2	<2	<2	<2	<2	<10	<2	<2	<10	<10			
Fluoride (ppm)	4	4	0.5	0.92	0.34	0.18	0.21	0.13	0.18	0.38	0.12	0.21	<0.1	0.42	<0.1-0.92	0.92	Erosion of Natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Chloride (mg/L)			22	94	79	18	47	33	28	48	47	35	25	76			
Sulfate (mg/L)			9	82	32	21	62	73	9	21	87	44	18	37			
Total Dissolved Solids (mg/L)			448	724	395	257	381	398	264	352	389	334	112	430			
Nitrate as N (ppm)	10	10	<0.05	0.13	<0.05	<0.05	<0.05	0.06	0.06	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05-0.13	0.13	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of Natural deposits.

Non Regulated

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Inorganics (Nitrate/Nitrite)**

Constituent	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2019	2019	2019	2019	2019	2019	2019	2020	2019	2019	2020	2020			
Nitrite as N (ppm)	1	1	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05			Runoff from fertilizer use; Leaching from septic, sewage; Erosion of natural deposits.
Year Sampled			2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2021			
Nitrate as N (ppm)	10	10	<0.05	0.13	<0.05	0.05	<0.05	0.06	0.06	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05-0.13	0.13	Runoff from fertilizer use; Leaching from septic, sewage; Erosion of natural deposits.

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Semivolatile Organic Compounds (Pesticides) SOC5**

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2019			
Chlordane (ppb)	0	2	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.2	<0.20			Residual of banned termiticide.
Endrin (ppb)	2	2	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01			Residual of banned insecticide.
Heptachlor epoxide (ppt)	0	200	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0			Breakdown of heptchlor
Toxaphene (ppb)	0	3	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			Runoff/leaching from insecticide used on cotton and cattle.



**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Semivolatile Organic Compounds (Herbicides)**

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020			
2,4-D (ppb)	70	70	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1			Runoff from herbicide used on row crops.
2,4,5-TP Silvex (ppb)	50	50	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2			Residue of banned herbicide.
Pentachlorophenol (ppb)	0	1	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04			Discharge from wood preserving factories.
Dalapon (ppb)	200	200	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1			Runoff from herbicide used on right of way.
Dinoseb (ppb)	7	7	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2			Runoff from herbicide used on soybeans and vegetables.
Picloram (ppb)	500	500	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1			Herbicide runoff.
Acifluorfen (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
Bentazon (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Chloraben (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
2,4-DB (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Dicamba (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
3,5-Dichlorobenzoic acid (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
Dichlorprop (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Quinclorac (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
2,4,5-T (µg/L)*			<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5			

\* Non Regulated Compounds



### Semivolatile Organic Compounds

[illegible]



Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2019			
Metolachlor (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
Meclorbutin (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
Naphthalene (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
2,2',3,3',4,5',6,6'-Octachlorobiphenyl (µg/L) *			<0.50	<0.50	<0.50	<0.51	<0.50	<0.50	<0.50	<0.51	<0.50	<0.51	<0.50	<0.50			
2,2',3',4,6-Pentachlorobiphenyl (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
Phenanthrene (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
Propachlor (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
Pyrene (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
2,2',4,4'-Tetrachlorobiphenyl (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
2,4,5-Trichlorobiphenyl (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
Trifluralin (µg/L) *			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20			
sulfur (µg/L) **									122								

\* Monitored Compounds [40 CFR 141.40(c)]

\*\* Tentatively Identified Compounds

\*\*\* Sampled three times during the year.

**Aqua Water Supply Corporation**  
**2021 Safe Drinking Water Sample Results**

**Volatile Organic Compounds**

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled			2021	2021	2021	2021	2021	2021	2021	2021	2021	2020	2021	2021				
Benzene (ppb)	0	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from factories; Leaching from gas storage tanks and landfills.
Carbon tetrachloride (ppb)	0	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from chemical plants and other industrial activities.
Monochlorobenzene (ppb)	100	100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from chemical and agricultural chemical factories.
o-Dichlorobenzene (ppb)	600	600	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from industrial chemical factories.
para-Dichlorobenzene (ppb)	75	75	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from industrial chemical factories.
1,2-Dichloroethane (ppb)	0	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from industrial chemical factories.
1,1-Dichloroethylene (ppb)	7	7	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from industrial chemical factories.
cis-1,2-Dichloroethylene (ppb)	70	70	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from industrial chemical factories.
trans-1,2-Dichloroethylene (ppb)	100	100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from industrial chemical factories.
1,2-Dichloropropane (ppb)	0	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from industrial chemical factories.
Dichloromethane (ppb)	0	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from pharmaceutical and chemical factories.
Ethylbenzene (ppb)	700	700	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from petroleum refineries.
Styrene (ppb)	100	100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from rubber and plastic factories; Leaching from landfills.
Tetrachloroethylene (ppb)	0	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Leaching from PVC pipes; Discharge from factories and dry cleaners.
Toluene (ppb)	1	1	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from petroleum factories.
1,2,4-Trichlorobenzene (ppb)	70	70	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.05	<0.5	<0.5				Discharge from textile-finishing factories.
1,1,1-Trichloroethane (ppb)	200	200	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.05	<0.5	<0.5				Discharge from metal degreasing sites and other factories.
1,1,2-Trichloroethane (ppb)	3	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.05	<0.5	<0.5				Discharge from industrial chemical factories.
Trichloroethylene (ppb)	0	5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.05	<0.5	<0.5				Discharge from metal degreasing sites and other factories.
Vinyl chloride (ppb)	0	2	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.05	<0.5	<0.5				Leaching from PVC pipes; Discharge from plastic factories.
Total Xylenes (ppb)	10	10	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5				Discharge from petroleum factories; Discharge from chemical factories.



Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled			2021	2021	2021	2021	2021	2021	2021	2021	2021	2020	2021	2021				
Chloroform (µg/L)*			3.1	1.5	<1.0	1.0	1.0	1.2	1.7	<1.0	<1.0	1.7	<1.0	<1.0	<1.0-3.1	1.6	3.1	
Bromodichloromethane (µg/L)*			3.9	3.2	<1.0	<1.0	2.6	1.5	2.1	1.0	1.5	3.5	<1.0	1.2	<1.0-3.9	2.3	3.9	
Dibromochloromethane (µg/L)*			3.9	5.1	<1.0	<1.0	3.6	1.6	1.8	1.8	2.3	4.6	<1.0	2.5	<1.0-5.1	3.0	5.1	
Bromoform (µg/L)*			1.3	4.0	1.3	<1.0	2.1	<1.0	<1.0	1.7	1.6	2.1	<1.0	3.4	<1.0-4.0	2.2	4.0	
Dibromomethane (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,3-Dichlorobenzene (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,1-Dichloropropene (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,1-Dichloroethane (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,1,2,2-Tetrachloroethane (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,3-Dichloropropane (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Chloromethane (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0				
Bromomethane (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0				
1,2,3-Trichloropropane (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,1,1,2-Tetrachloroethane (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Chloroethane (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0				
2,2-Dichloropropane (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
2-Chlorotoluene (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
4-Chlorotoluene (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Bromobenzene (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
cis-1,3-Dichloropropene (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
trans-1,3-Dichloropropene (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,2,4-Trimethylbenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,2,3-Trichlorobenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
n-Propylbenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
n-Butylbenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Naphthalene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Hexachlorobutadiene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
1,3,5-Trimethylbenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
4-Isopropyltoluene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Isopropylbenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
t-Butylbenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
s-Butylbenzene (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Trichlorofluoromethane (µg/L)**			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0				
Dichlorodifluoromethane (µg/L)**			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0				
Bromochloromethane (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Acetone (µg/L)**			<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10				
Acrylonitrile (µg/L)**			<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10				
2-Butanone MEK (µg/L)**			<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10				
Carbon disulfide (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Ethyl methacrylate (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
2-Hexanone (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
Iodomethane (µg/L)**			<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0				
Methyl Methacrylate (µg/L)**			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0				
4-Methyl-2-pentanone MIBK (µg/L)**			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0				
Methyl-t-butyl ether MTBE (µg/L)**			<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<2.0	<0.5	<0.5	<2.0	<2.0				
Tetrahydrofuran (µg/L)**			<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0				
Vinyl acetate (µg/L)**																		

\* Monitored Compounds [40 CFR 141.40(e)]

\*\* Monitored Compounds [40 CFR 141.40(j)]

\*\*\* Other Compounds



**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Organics (EDB & DBCP)**

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020			
Ethylene dibromide (ppt)	0	50	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0			Discharge from petroleum refineries
Dibromochloropropane (ppt)	0	200	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0			Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards.
1,2,3-Trichloropropane (µg/L)*			<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05			

\* Non Regulated Compound

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Organics (Carbamates by HPLC)**

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Highest	Likely Source
Year Sampled			2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020	2020			
Aldicarb (µg/L)		3	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5			
Aldicarb sulfone (µg/L)		2	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8			
Aldicarb Sulfoxide (µg/L)		4	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5			
Carbofuran (ppb)	40	40	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9			Leaching from soil fumigant used on rice and alfalfa.
Oxamyl (ppb)	200	200	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			Runoff/leaching from insecticide used on apples, potatoes, and tomatoes.
Baygon (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Carbaryl (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
3-Hydroxycarbofuran (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Methiocarb (µg/L)*			<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0			
Methomyl (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			

\* Monitored Compounds

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Disinfection Byproducts (Distribution)**

Contaminate	MCLG	MCL	8483 FM 713 (DBP1-01)	118 Sayers Road (DBP1-01)	125 Keller (DBP1-03)	154 FM 2239 (DBP1-04)	170 Loop Road (DBP1- 05)	17818 Lund Carlson (DBP1 06)	2854 E Hwy 71 (DBP1-07)	4184 FM 696 (DBP1-08)	5384 FM 696 (DBP1-09)	6108 Hwy 304 (DBP1-10)	FM 20 & Brite Road (DBP1-11)	RT 2 Box 140 Hwy 290 (DBP1-12)	Range	Highest	Average	Likely Source
Year Sampled			2011	2011	2011	2011	2011	2011	2011	2011	2011	2011	2011	2011				
Total HAA5 (ppb)	n/a	60.0	3.7	1.6	3.2	12.8	<6.0	2.1	3.6	<6.0	1.3	<6.0	1.2	2.5	<6.0-12.8	12.8	3.6	By-product of drinking water disinfection.
Total THM (µg/L)	n/a	80.0	16.8	13.1	24.3	31.4	1.4	30.7	36.6	6.9	9.2	<4.0	10.1	14.9	<4.0-36.6	36.6	17.8	By-product of drinking water disinfection.



**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Unregulated Contaminants Monitoring Rule III**

**Entry Points**

**Volatile Organic Compounds (VOC)**

Contaminate	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chlorodifluoromethane (HCFC-22)	µg/L	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800			0	
Chloromethane (Methyl chloride)	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200			0	
1,3-Butadiene	µg/L	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100			0	
Bromomethane (Methyl Bromide)	µg/L	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2			0	
1,1-Dichloroethane	µg/L	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300			0	
Bromochloromethane (Halon 1011)	µg/L	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600			0	
1,2,3-Trichloropropane	µg/L	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300			0	

**Synthetic Organic Compounds (SOC)**

Contaminate	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
1,4-Dioxane	µg/L	<0.0516	<0.0521	<0.0518	<0.0522	<0.0523	<0.0525	<0.0526	<0.0519	<0.0523	<0.0525	<0.0529	<0.0521			0	

**Oxyhalide Anion**

Contaminate	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chlorate	µg/L	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	29.5	<20.0	<20.0-29.5	29.5	29.5	

**Metals**

Contaminate	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chromium Total	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200			0	
Cobalt Total	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	2.51	<1.00	<1.00-2.51	2.51	2.51	
Molybdenum Total	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00			0	
Strontium Total	µg/L	279	964	462	1050	457	891	64	401	4210	1210	63.5	1370	63.5-4210	952	4210	
Vanadium Total	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	1.41	<0.200	<0.200-1.41	1.41	1.41	
Hexavalent Chromium	µg/L	0.0469	0.0371	<0.0300	0.0569	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	0.133	<0.0300	<0.0300-0.133	0.07	0.133	

**Perfluorinated Compounds**

Contaminate	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Perfluorobutanesulfonic acid (PFBS)	µg/L	<0.0818	<0.0806	<0.0801	<0.0815	<0.0825	<0.0858	<0.0815	<0.0818	<0.0822	<0.0788	<0.0800	<0.0804			0	
Perfluorohexanesulfonic acid (PFHxS)	µg/L	<0.0307	<0.0302	<0.0300	<0.0305	<0.0309	<0.0322	<0.0306	<0.0307	<0.0308	<0.0296	<0.0300	<0.0301			0	
Perfluoroheptanoic acid (PFHpA)	µg/L	<0.0102	<0.0101	<0.0100	<0.0102	<0.0103	<0.0107	<0.0102	<0.0102	<0.0103	<0.00985	<0.0100	<0.0100			0	
Perfluorononanoic acid (PFNA)	µg/L	<0.0205	<0.0201	<0.0200	<0.0204	<0.0206	<0.0215	<0.0204	<0.0205	<0.0206	<0.0197	<0.0200	<0.0201			0	
Perfluorooctanoic acid (PFOA)	µg/L	<0.0205	<0.0201	<0.0200	<0.0204	<0.0206	<0.0215	<0.0204	<0.0205	<0.0206	<0.0197	<0.0200	<0.0201			0	
Perfluorooctanesulfonic acid (PFOS)	µg/L	<0.0409	<0.0403	<0.0400	<0.0407	<0.0413	<0.0429	<0.0407	<0.0409	<0.0411	<0.0394	<0.0400	<0.0402			0	

# Distribution Points

## Oxyhalide Anion

Contaminate	Units	1472 FM 2571 (1)	Buddha Temple (2)	New Sweden Church (3)	(4)	Word of Life Church (5)	La Cabana (6)	154 FM 2239 (7)	568 Pleasant Grove Road (8)	Blue VFD (9)	Knobbs Baptist Church (10)	Centex (11)	Jack Chamberlain (12)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chlorate	µg/L	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	31.3	<20.0	<20.0-31.3	31.3	31.3	

## Metals

Contaminate	Units	1472 FM 2571 (1)	Buddha Temple (2)	New Sweden Church (3)	(4)	Word of Life Church (5)	La Cabana (6)	154 FM 2239 (7)	568 Pleasant Grove Road (8)	Blue VFD (9)	Knobbs Baptist Church (10)	Centex (11)	Jack Chamberlain (12)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chromium Total	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200			0	
Cobalt Total	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00			0	
Molybdenum	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00			0	
Strontium	µg/L	608	720	457	469	485	1030	62.6	4150	668	1320	73.8	1350	62.6-4150	949	4150	
Vanadium	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	1.60	<0.200	<0.200-1.60	1.60	1.60	
Hexavalent Chromium	µg/L	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	0.0325	<0.0300	<0.0300	<0.0300	0.0353	0.1230	<0.0300	<0.0300-0.1230	0.0636	0.1230	



**Aqua Water Supply Corporation**  
**2021 Safe Drinking Water Sample Results**

**Unregulated Contaminants Monitoring Rule III**

**Entry Points**

**Volatile Organic Compounds (VOC)**

Contaminant	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chlorodifluoromethane (HCFC-22)	µg/L	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800	<0.0800			0	
Chloromethane (Methyl chloride)	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200			0	
1,3-Butadiene	µg/L	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100	<0.100			0	
Bromomethane (Methyl Bromide)	µg/L	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2			0	
1,1-Dichloroethane	µg/L	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300			0	
Bromochloromethane (Halon 1011)	µg/L	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600	<0.0600			0	
1,2,3-Trichloropropane	µg/L	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300			0	

**Synthetic Organic Compounds (SOC)**

Contaminant	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
1,4-Dioxane	µg/L	<0.0516	<0.0521	<0.0518	<0.0522	<0.0523	<0.0525	<0.0526	<0.0519	<0.0523	<0.0525	<0.0529	<0.0521			0	

**Oxyhalide Anion**

Contaminant	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chlorate	µg/L	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	29.5	<20.0	<20.0-29.5	29.5	29.5	

**Metals**

Contaminant	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chromium Total	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200			0	
Cobalt Total	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	2.51	<1.00	<1.00-2.51	2.51	2.51	
Molybdenum Total	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00			0	
Strontium Total	µg/L	279	964	462	1050	457	891	64	401	4210	1210	63.5	1370	63.5-4210	952	4210	
Vanadium Total	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	1.41	<0.200	<0.200-1.41	1.41	1.41	
Hexavalent Chromium	µg/L	0.0469	0.0371	<0.0300	0.0569	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	0.133	<0.0300	<0.0300-0.133	0.07	0.133	

**Perfluorinated Compounds**

Contaminant	Units	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Perfluorobutanesulfonic acid (PFBS)	µg/L	<0.0818	<0.0806	<0.0801	<0.0815	<0.0825	<0.0858	<0.0815	<0.0818	<0.0822	<0.0788	<0.0800	<0.0804			0	
Perfluorohexanesulfonic acid (PFHxS)	µg/L	<0.0307	<0.0302	<0.0300	<0.0305	<0.0309	<0.0322	<0.0306	<0.0307	<0.0308	<0.0296	<0.0300	<0.0301			0	
Perfluoroheptanoic acid (PFHpA)	µg/L	<0.0102	<0.0101	<0.0100	<0.0102	<0.0103	<0.0107	<0.0102	<0.0102	<0.0103	<0.00985	<0.0100	<0.0100			0	
Perfluorononanoic acid (PFNA)	µg/L	<0.0205	<0.0201	<0.0200	<0.0204	<0.0206	<0.0215	<0.0204	<0.0205	<0.0206	<0.0197	<0.0200	<0.0201			0	
Perfluorooctanoic acid (PFOA)	µg/L	<0.0205	<0.0201	<0.0200	<0.0204	<0.0206	<0.0215	<0.0204	<0.0205	<0.0206	<0.0197	<0.0200	<0.0201			0	
Perfluorooctanesulfonic acid (PFOS)	µg/L	<0.0409	<0.0403	<0.0400	<0.0407	<0.0413	<0.0429	<0.0407	<0.0409	<0.0411	<0.0394	<0.0400	<0.0402			0	

# Distribution Points

## Oxyhalide Anion

Contaminate	Units	1472 FM 2571 (1)	Buddha Temple (2)	New Sweden Church (3)	(4)	Word of Life Church (5)	La Cabana (6)	154 FM 2239 (7)	568 Pleasant Grove Road (8)	Blue VFD (9)	Knobbs Baptist Church (10)	Centex (11)	Jack Chamberlain (12)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chlorate	µg/L	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	31.3	<20.0	<20.0-31.3	31.3	31.3	

## Metals

Contaminate	Units	1472 FM 2571 (1)	Buddha Temple (2)	New Sweden Church (3)	(4)	Word of Life Church (5)	La Cabana (6)	154 FM 2239 (7)	568 Pleasant Grove Road (8)	Blue VFD (9)	Knobbs Baptist Church (10)	Centex (11)	Jack Chamberlain (12)	Range	Average	Highest	Likely Source
Year Sampled		2014															
Chromium Total	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200			0	
Cobalt Total	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00			0	
Molybdenum	µg/L	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00			0	
Strontium	µg/L	608	720	457	469	485	1030	62.6	4150	668	1320	73.8	1350	62.6-4150	949	4150	
Vanadium	µg/L	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	<0.200	1.60	<0.200	<0.200-1.60	1.60	1.60	
Hexavalent Chromium	µg/L	<0.0300	<0.0300	<0.0300	<0.0300	<0.0300	0.0325	<0.0300	<0.0300	<0.0300	0.0353	0.1230	<0.0300	<0.0300-0.1230	0.0636	0.1230	



**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

DBP - 2

Contaminate	MCLG	MCL	Date	154 FM 2239 (DBP2-1)	5554 FM 535 Cedar Creek VFD (DBP2-2)	Bateman Road & Red Rock Ranch Rd. (DBP2-3)	973 & New Sweden Rd. Bohls Tank (DBP2-4)	Range	Highest	Likely Source
Year Sampled				2021	2021	2021	2021			
Total HAA5 (ppb)			2/2/2021	7.4	4.3	4.5	6.7	3.4 - 14.2	14.2	By-products of drinking water disinfection.
			4/12/2021	8.0	3.4	8.4	7.0			
			7/26/2021	8.8	11.1	13.7	14.2			
			11/29/2021	10.6	5.9	7.3	9.2			
Locational Running Annual Average	N/A	60.0		8.7	6.2	8.5	9.3			
Operational evaluation Level				9.5	6.6	9.2	9.9			
Total THM (ppb)			2/2/2021	21.3	47.1	39.4	41.3	20.5 - 78.7	78.7	By-products of drinking water disinfection.
			4/12/2021	20.5	37.4	44.1	46.1			
			7/26/2021	25.5	67.9	64.8	78.7			
			11/29/2021	25.5	45.3	44.2	53.0			
Locational Running Annual Average	N/A	80.0		23.2	49.4	48.1	54.8			
Operational evaluation Level				24.3	49.0	49.3	57.7			

Not Bold = less than the DL

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Lead/Copper**

Year Sampled	MCLG	MCL (Action Level)	90th Percentile Value	# Site Above Action Limit	Likely Source
			2020	2020	
Copper (ppm)	1.3	1.3	0.186	0	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead (ppb)	0	15	5	1	Corrosion of household plumbing systems; Erosion of natural deposits.

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Asbestos**

Contaminate	MCLG	MCL	1034 CR 337	Range	Highest	Likely Source
Year Sampled			2013			
Asbestos (MFL)	7	7	<0.1987			Decay of asbestos cement water mains; Erosion of natural deposits.

MFL = Million fibers per liter.

**Aqua Water Supply Corporation**  
**2021 Safe Drinking Water Sample Results**

**Residual Disinfectant**

Contaminate	MRDLG	MCL	Average	Range	Likely Source
Year Sampled			2019	2019	
Chlorine (ppm)	4	4	1.83	0.71-3.75	Water additive used to control microbes.

MRDLG = Maximum residual disinfectant level goal.

MRDL = Maximum residual disinfectant level.

**Aqua Water Supply Corporation  
2021 Safe Drinking Water Sample Results**

**Microbial**

Contaminate	MCLG	MCL	2018		Likely Source
Total Coliform Bacteria	0	Presence of More Than 5% of Monthly Samples	Highest Monthly % Positive Samples	0	Naturally present in the environment.
Fecal Coliforms and <i>E. coli</i>	0	A routine sample and a repeat sample are TC positive, and one is also fecal coliform or <i>E. coli</i> positive. An uncorrected <i>E. coli</i> -positive sample at the raw groundwater source is a TT for the GWR.	Total # Positive Samples.	0	Human and animal fecal waste.

TC = Total Coliform.

TT = Treatment Technique

GWR = Groundwater Rule.