

# 2023 Consumer Confidence Report for Public Water System BASTROP COUNTY MUD 1

This is your water quality report for January 1 to December 31, 2023

BASTROP COUNTY MUD 1 provides Purchased Ground Water from Carrizo - Wilcox aquifer located in Bastrop County.

For more information regarding this report contact:

Name Bastrop County MUD 1

Phone (512) 402-1990

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al teléfono (512) 402-1990.

## Definitions and Abbreviations

Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picocuries per liter (a measure of radioactivity)

## **Definitions and Abbreviations**

ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

## **Information about your Drinking Water**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Information about Source Water

BASTROP COUNTY MUD 1 purchases water from AQUA WSC. AQUA WSC provides purchase ground water from the Carrizo - Wilcox aquifer located in Bastrop County.

TCEQ completed a Source Water Susceptibility for all drinking water systems that own their sources. This report describes the susceptibility and types of constituents that may come into contact with the drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system contact Bastrop County MUD #1 at 512-402-1990.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2023	1.3	1.3	0.205	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems

## 2023 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
--------------------------	-----------------	------------------------	-----------------------------	------	-----	-------	-----------	--------------------------------

Haloacetic Acids (HAA5)	06/29/2021	5.6	5.6 - 5.6	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	06/29/2021	25.6	25.6 - 25.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate [measured as Nitrogen]	2023	0.06	0.06 - 0.06	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

## Disinfectant Residual

A blank disinfectant residual table has been added to the CCR template, you will need to add data to the fields. Your data can be taken off the Disinfectant Level Quarterly Operating Reports (DLQOR).

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine(Free)	2023	1.8	1.3 - 2.4	4	4	ppm	N	Water additive used to control microbes.

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Inorganics (Nitrate/Nitrite)**

Contaminant	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2019	2019	2019	2019	2019	2019	2019	2020	2019	2019	2020	2020	2023	2023	2023			
Nitrite as N (ppm)	1	1	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05		Runoff from fertilizer use; Leaching from septic, sewage; Erosion of natural deposits.	
Year Sampled			2023	2022	2021	2022	2022	2022	2022	2023	2022	2022	2023	2023	2021	2021	2022			
Nitrate as N (ppm)	10	10	0.07	0.12	<0.05	0.05	<.05	0.06	0.07	<0.05	<0.05	<0.05	0.05	<0.05	<0.05	0.15	<0.05	<0.05-0.15	0.15	Runoff from fertilizer use; Leaching from septic, sewage; Erosion of natural deposits.

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Semivolatile Organic Compounds (Pesticides) SOC5**

Contaminant	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2022	2023	2023	2023				
Chlordane (ppb)	0	2	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20				
Endrin (ppb)	2	2	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01		Residual of banned termiticide.	
Heptachlor epoxide (ppt)	0	200	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0		Residual of banned insecticide.	
Toxaphene (ppb)	0	3	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0		Breakdown of heptachlor	
Arclor 1016 <sup>2</sup>																			Runoff/leaching from insecticide used on cotton and cattle.	
Aroclor 1221 <sup>2</sup>																				
Aroclor 1232 <sup>2</sup>																				
Aroclor 1242 <sup>2</sup>																				
Aroclor 1248 <sup>2</sup>																				
Aroclor 1254 <sup>2</sup>																				
Aroclor 1260 <sup>2</sup>																				

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Inorganics (Single Mineral)**

Contaminant	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2023	2023	2020	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023				
Cyanide (ppb)	200	200	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0			Discharge from steel/metal factories; Discharge from plastic and fertilizer factories.	

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Asbestos**

Contaminant	MCLG	MCL	1054 CR 337	5992 CR 139	3360 Homanville Dr	3223 San Holler Rd	Range	Highest	Likely Source
Year Sampled									
Asbestos (MFL)	7	7	<0.197	<0.197	<0.197	<0.197			Decay of asbestos cement water mains; Erosion of natural deposits.

MFL = Million fibers per liter.

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Residual Disinfectant**

Contaminant	MRDLG	MCL	Average	Range	Likely Source
Year Sampled	2023				
Chlorine (ppm)	4	4	1.7	0.57-3.68	Water additive used to control microbes.

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Microbial**

Contaminant	MCLG	MCL	2023	Likely Source
Total Coliform Bacteria	0	Presence of More Than 5% of Monthly Samples	Highest Monthly % Positive Samples	0 Naturally present in the environment.
Fecal Coliforms and <i>E. coli</i>	0	A routine sample and a repeat sample are TC positive, and one is also fecal coliform or <i>E. coli</i> positive. An uncorrected <i>E. coli</i> -positive sample at the raw groundwater source is a TT for the GWR.	Total # Positive Samples.	0 Human and animal fecal waste.

TC = Total Coliform.

TT = Treatment Technique

GWR = Groundwater Rule.

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Radiochemicals**

Contaminant (Units)	MCL	MCLG	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2023	2023	2017	2023	2023	2023	2023	2021	2023	2020	2021	2021	2023	2023	2023			
Gross Beta Particles (pCi/L)	50	0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	5.3	5.2	5.4	4.4	5.8	5.0	4.7	<4.0-5.8	5.8	Decay of natural and man-made deposits.
Gross Alpha Excluding Radon/Uranium (pCi/L)	15	0	3.6	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0-3.6	3.6	Erosion of natural deposits.
Uranium (ppb)	30	0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	Erosion of natural deposits.

Contaminant (Units)	MCL	MCLG	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2002																	
Radium-226 (pCi/L)	5		0.2																	
Year Sampled	5		2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023			
Radium-228 (pCi/L)			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	1.12	<1.0-1.12	1.1	
Year Sampled	2																			
Combined radium (-226 & -228)																				

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

Semivolatile Organic Compounds (Herbicides)

Contaminant	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2023	2023	2020	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023			
2,4-D (ppb)	70	70	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1		Runoff from herbicide used on row crops.	
2,4,5-TP Silvex (ppb)	50	50	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2		Residue of banned herbicide.	
Pentachlorophenol (ppb)	0	1	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04		Discharge from wood preserving factories.	
Dalapon (ppb)	200	200	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1		Runoff from herbicide used on right of way.	
Dinoseb (ppb)	7	7	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2		Runoff from herbicide used on soybeans and vegetables.	
Picloram (ppb)	500	500	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1		Herbicide runoff.	
Acifluorfen (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
Bentazon (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Chlorben (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
2,4-DB (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Dicamba (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
3,5-Dichlorobenzoic acid (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
Dichlorprop (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Quinclorac (µg/L)*			<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0			
2,4,5-T (µg/L)*			<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5			

\* Non Regulated Compounds

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

Organics (Carbamates by HPLC)

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2023	2023	2020	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023			
Aldicarb (µg/L)	3	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5		
Aldicarb sulfone (µg/L)	2	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<0.8		
Aldicarb Sulfoxide (µg/L)	4	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5		
Carbofuran (ppb)	40	40	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9	Leaching from soil fumigant used on rice and alfalfa.	
Oxamyl (ppb)	200	200	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	Runoff/leaching from insecticide used on apples, potatoes, and tomatoes.	
Baygon (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0		
Carbaryl (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0		
3-Hydroxycarbofuran (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0		
Methiocarb (µg/L)*			<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0	<4.0		
Methylomyl (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0		

\* Monitored Compounds

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

Organics (EDB & DBCP)

Contaminate	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2023	2023	2020	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023	2023			
Ethylene dibromide (ppt)	0	50	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	Discharge from petroleum refineries	
Dibromochloropropane (ppt)	0	200	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards.	
1,2,3-Trichloropropene (µg/L)*			<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05		

\* Non Regulated Compound

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

DBP - 2

Contaminate	MCLG	MCL	Date	154 FM 2239 (DBP2-1)	5554 FM 535 Cedar Creek VFD (DBP2-2)	Bateman Road & Red Rock Ranch Rd. (DBP2-3)	973 & New Sweden Rd. Bohls Tank (DBP2-4)	Range	Highest	Likely Source
Year Sampled				2023	2023	2023	2023			
Total HAA5 (ppt)			1/23/2023	7.6	6.7	6.5	6.1			
			4/18/2023	11.1	6.4	10.3	9.3			
			7/13/2023	7.6	6.6	11.5	8.0			
			10/2/2023	14.3	10.9	9.8	7.8			
Locational Running Annual Average	N/A	60.0		10.2	7.7	9.5	7.8			
Operational evaluation Level				13.7	10.4	12.0	9.8			
Total THM (ppt)			1/23/2023	22.7	62.2	54.1	42.7			
			4/18/2023	27.9	51.0	56.0	49.7			
			7/13/2023	22.8	57.7	77.0	43.4			
			10/2/2023	27.3	87.6	73.2	46.8			
Locational Running Annual Average	N/A	80.0		25.2	64.6	65.1	45.7			
Operational evaluation Level				32.0	86.5	83.4	57.4			

Not Bold = less than the DL

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Inorganics (All Metals)**

Contaminant	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2023	2023	2020	2023	2023	2022	2022	2021	2022	2023	2021	2021	2023	2023	2023	2023	2023	
Total Hardness as CaCO <sub>3</sub> by Cal. (mg/L)			15.6	42.2	158	45.9	242	38.7	2.85	178	177	106	22.4	152	359	228	451	2.85-452	451	
Aluminum (mg/L)			<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02		
Antimony (ppb)	6	6	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0		Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.	
Arsenic (ppb)	10	10	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.	
Barium (ppm)	2	2	0.0633	0.0817	0.1450	0.127	0.115	0.0392	0.0117	0.1100	0.0383	0.157	0.0797	0.0798	0.0918	0.0968	0.119	0.0117-0.157	0.157	
Beryllium (ppb)	4	4	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	<0.80	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries.	
Cadmium (ppb)	5	5	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints.	
Calcium (mg/L)			3.46	8.57	48	11.5	80.1	9.69	1.14	55.1	48.1	29.0	6	35.1	106	60.6	144	1.14-144	144	
Chromium (ppb)	100	100	<10	<10	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10.0	<10	<10	<10	<10.0	Discharge from steel and pulp mills; Erosion of natural deposits.	
Copper (mg/L)			0.0162	0.0379	0.0025	0.0263	0.0043	0.0129	0.008	0.0026	0.0203	0.0231	<0.002	0.003	0.0052	0.0029	0.0022	<0.0020-0.0379	0.0379	
Iron (mg/L)			0.010	0.024	0.011	0.081	0.064	0.037	<0.01	0.012	<0.01	<0.01	0.014	<0.01	<0.01	<0.01	<0.01	<0.010-0.081	0.081	
Lead (mg/L)			<0.001	<0.001	<0.001	<0.001	0.0013	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001-0.0013	0.0013	
Magnesium (mg/L)			1.70	5.05	9.26	4.17	10.2	3.51	<1.00	9.72	13.8	8.16	1.8	15.7	23.0	18.5	22.3	<1.0-23	23.0	
Manganese (mg/L)			0.0053	0.0105	0.0016	0.0148	0.0055	0.0129	0.0031	<0.001	0.0011	<0.001	<0.001	<0.001	<0.0010	0.0022	<0.001-0.0148	0.0148		
Mercury (ppb)	2	2	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40		Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland.	
Nickel (mg/L)			<0.001	<0.001	<0.001	<0.001	0.0014	<0.001	<0.001	0.001	0.0013	<0.001	0.0079	<0.001	0.0024	0.0015	0.0033	<0.001-0.0079	0.0079	
Potassium (mg/L)			2.17	2.38	2.46	2.42	3.02	2.84	<1.00	2.58	4.44	3.03	5.73	3.51	5.48	4.66	3.76	<1.00-5.73	5.73	
Selenium (ppb)	50	50	<3.0	0.0057	5.5	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	<3.0	3.5	3.1	5.9	<3.0-5.9	5.9	
Silver (mg/L)			<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01		
Sodium (mg/L)			165	279	77.7	75	27.6	133	96.6	54.6	60.7	61.9	15.6	113	45	87.7	75.4	15.6-279	279	
Thallium (ppb)	0.5	2	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40	<0.40		Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories.	
Zinc (mg/L)			<0.005	0.0053	0.0121	0.007	<0.005	<0.005	0.0078	<0.005	0.0065	<0.005	0.0334	<0.005	0.0099	<0.005	<0.005	<0.005-0.0334	0.0334	

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Inorganics (Minerals)**

Constituent	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Dale Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2023	2023	2020	2023	2023	2023	2023	2023	2021	2023	2021	2021	2023	2023	2023			
pH (S.U.)			7.8	7.9	7.7	7.5	7.1	7.5	7.9	8.1	7.7	7.6	8.5	8.4	8.0	8.2	8.1	7.1-8.5	8.5	
Diluted Conductance (μmho/cm)			755	1390	735	420	652	707	453	604	693	508	150	831	1040	912	1380	150-1390	1390	
Phenolphthalein Alkalinity as CaCO <sub>3</sub> (mg/L)			13	<10	<2	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<2-13	13	
Total Alkalinity as CaCO <sub>3</sub> (mg/L)			363	463	212	167	177	223	197	203	173	183	16	249	187	220	270	16-463	463	
Bicarbonate (mg/L)			411	565	259	204	216	272	240	248	211	215	20	300	228	268	329	20-565	565	
Carbonate (mg/L)			16	<10	<2	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10	<2-16	16	
Fluoride (ppm)	4	4	0.46	1.04	0.34	0.16	0.21	0.13	0.16	0.38	0.12	0.18	<0.1	0.42	0.14	0.54	0.19	<0.1-1.04	1.04	
Chloride (mg/L)			21	111	79	17	47	34	26	48	45	27	25	76	135	83	195	17-195	195	
Sulfate (mg/L)			9	64	32	20	62	76	9	21	86	32	18	37	92	88	86	9-92	92	
Total Dissolved Solids (mg/L)			442	773	395	238	367	409	269	352	393	292	112	430	571	506	756	112-773	773	
Nitrate as N (ppm)	10	10	<0.05	0.11	<0.05	<0.05	<0.05	0.07	0.06	<0.05	0.08	<0.05	<0.05	<0.05	<0.05	0.15	<0.05	<0.05-0.15	0.15	
Non Regulated																			Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of Natural deposits.	

**Aqua Water Supply Corporation**  
**2023 Safe Drinking Water Sample Results**

**Semivolatile Organic Compounds**

Contaminant	MCLG	MCL	Rosanky (1)	S (2)	ER (3)	Highway 21 (4)	Camp Swift (5)	M (6)	L (7)	C (8)	Blue (9)	McDade (13)	Delhi (15)	McMahan (16)	Polonia Main(17)	Date Polonia North(18)	Polonia South(19)	Range	Highest	Likely Source
Year Sampled			2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2021	2022	2023	2023	2023			
Alachlor (ppb)	0	2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	Rainoff from herbicide used on row crops.	
Atrazine (ppb)	3	3	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	Rainoff from herbicide used on row crops.	
Benz(a)pyrene (ppt)	0	200	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	Leaching from linings of water storagetanks and distribution lines.	
alpha-Chlordane (ppb)	0	2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	Residue of banned herbicide.	
gamma-Chlordane (ppb)	0	2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	Residue of banned herbicide.	
trans-Nonachlor (ppb)	0	2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	Rainoff from herbicide used on row crops.	
Di(2-ethylhexyl) adipate (ppb)	400	400	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	Discharge from chemical factories.	
Di(2-ethylhexyl) phthalate (ppb)	0	6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	Discharge from rubber and chemical factories.	
Heptachlor (ppt)	0	400	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	<40.0	Residue of banned termiticide.	
Hexachlorobenzene (ppb)	0	1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	Discharge from metal refineries and agricultural chemical factories.	
Hexachlorocyclopentadiene (ppb)	50	50	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	Discharge from chemical factories.	
Lindane (ppt)	200	200	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	<20.0	Rainoff/leaching from insecticide used on cattle, lumber, gardens.	
Methoxychlor (ppb)	40	40	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	Rainoff/leaching from insecticide used on fruits, vegetables, alfalfa, and livestock.	
Simazine (ppb)	4	4	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	<0.07	Herbicide runoff.	
Acenaphthene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Acenaphthylene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Aldrin (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Anthracene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Benz(a)anthracene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Benz(b)fluoranthene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Benz(e,i)perylene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Benz(k)fluoranthene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Bromacil (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Butachlor (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Butylbenzene Phthalate (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.1	
2-Chlorophenol (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Chrysene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Dibenzo(a,h)anthracene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Di-n-butylphthalate (µg/L)*			<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.1	
2,3-Dichlorobiphenyl (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Indeno[1,2,3-cd]pyrene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Metachlor (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Metribuzin (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Naphthalene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
2,2',3,3',4,5,6-Octachlorobiphenyl (µg/L)*			<0.50	<0.50	<0.50	<0.51	<0.50	<0.50	<0.50	<0.51	<0.50	<0.51	<0.50	<0.51	<0.50	<0.50	<0.50	<0.51	<0.53	
2,2',3,4,5,6-Hexachlorobiphenyl (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Phenanthrene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Propachlor (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Pyrene (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
2,2',3,4-Tetrachlorobiphenyl (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
2,4,5-Trichlorobiphenyl (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
Trifluralin (µg/L)*			<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.21	
sulfur (µg/L)**																				

\* Monitored Compounds [40 CFR 141.40(c)]

\*\* Tentatively Identified Compounds

Aqua Water Supply Corporation  
2023 Safe Drinking Water Sample Results

## Volatile Organic Compounds

\* Monitored Compounds [40 CFR 141.40(c)]

**\*\* Monitored Compounds [40 CFR 141.40(j)]**

#### \*\*\* Other Compound